



Single Vane Schedule			
	R	SP	GA
Small	2"	1 1/2"	24
	(51 mm)	(38 mm)	(0.70 mm)
Large	4 1/2"	3 1/4"	22
	(114 mm)	(83 mm)	(0.85 mm)

See notes on fig.2-4. Other runners may be used as appropriate. Other vane sizes, spacings or configurations are acceptable on designer approval.

As Described on page 2.5, Figure 2-3 of the SMACNA HVAC Duct Construction Standards, 2nd Ed., 1995.

